



Certificate of Compliance

No. LVD19-8065

About the Low Voltage Directive 2014/35/EU

Applicant:

Guangdong WEIPU Electrical Appliance Co., Ltd.
NO.3 Puling road, Dayan industrial estate,
Huangpu town, Zhongshan city, Guangdong

Product/Material:

Flush-type Socket-outlet for Industrial Purposes

Trade Mark:

—

Model/Type:

TYP 3623, TYP 5623, TYP 3618, TYP 5618, TYP 3601, TYP 5601,
TYP 3624, TYP 5624, TYP 3619, TYP 5619, TYP 3602,
TYP 5602, TYP 3523, TYP 3518, TYP 3501, TYP 5101, TYP 4601

Rated Specification:

See appendix

Tested According to:

EN 60309-1:1999+A1:2007+A2:2012,
EN 60309-2:1999+A1:2007+A2:2012

**Referred to the
Technical Report:**


RZCE2019-0421LVD

This certificate of conformity is based on an evaluation of a tested sample of the product mentioned above. It does not imply assessment of series-production of the product. The applicant should hold the whole technical report at the disposal of the competent authority.

Provided it is also confirmed with any other EU directives, the manufacturer or its authorized European representative may draw up an EC/EEA Declaration of Conformity and affix the CE-mark shown below to each conforming product.



中国认可
国际互认
检测
TESTING
CNAS L0095



Vkan Certification & Testing Co., Ltd.
No.3, Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, 510663, P.R. China
Tel.: +86-20-32293888, Fax: +86-20-32293889. E-mail: office@cvc.org.cn
www.cvc.org.cn

Xie haojiang
Director of CVC
Date of Issue: Nov. 21, 2019

LTC-C-0001-LVD-G2



Certificate of Compliance

APPENDIX to C.O.C No. LVD19-8065

Rated Specification:

TYP 3623, TYP 5623 16A-6h/415V~ 3P+N+PE IP44,
TYP 3618, TYP 5618 16A-6h/415V~ 3P+PE IP44,
TYP 3601, TYP 5601 16A-6h/250V~ 2P+PE IP44,
TYP 3624, TYP 5624 16A-6h/415V~ 3P+N+PE IP67,
TYP 3619, TYP 5619 16A-6h/415V~ 3P+PE IP67,
TYP 3602, TYP 5602 16A-6h/250V~ 2P+PE IP67,
TYP 3523 16A-6h/415V~ 3P+N+PE IP44,
TYP 3518 16A-6h/415V~ 3P+PE IP44,
TYP 3501, TYP 5101, TYP 4601 16A-6h/250V~ 2P+PE IP44



中国认可
国际互认
检测
TESTING
CNAS L0085



Signed by:

Xie haojiang

Xie haojiang

Director of CVC

Date of Issue: Nov. 21, 2019

Vkan Certification & Testing Co., Ltd.

No.3, Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, 510663, P.R. China

Tel.: +86-20-32293888, Fax: +86-20-32293889. E-mail: office@cvc.org.cn

www.cvc.org.cn

LTC-C-0001-LVD-G2